

CCS&ES		DAILY LOG SHEET		CCS-RTOX
PROJECT NAME		PROJECT NUMBER		

Date _____ Time _____ am /pm Operator Initials _____

ITEM	NORMAL	OBSERVED
OUTDOR EQUIPMENT		
Exhaust Fan		
Exhaust Fan Noise (Yes/No/Specify)	N	<input type="checkbox"/> Y <input type="checkbox"/> N
Exhaust Fan Vibration (Normal/Abnormal)	N	<input type="checkbox"/> Y <input type="checkbox"/> A
Pneumatic System		
Supply Pressure (PSIG)	100	
Tire Pressure (PSIG)	55-65	
Are there any Pneumatic Leaks (Yes/No/Specify)	N	<input type="checkbox"/> Y <input type="checkbox"/> N
<i>(Observe one (1) complete Valve Cycle)</i>		
Is the Pin Cylinder Operating Freely (Yes/No/Specify)	Y	<input type="checkbox"/> Y <input type="checkbox"/> N
Is the Drive Cylinder Operating Freely (Yes/No/Specify)	Y	<input type="checkbox"/> Y <input type="checkbox"/> N
Gas Train		
Gas Supply Pressure (PSIG)	5	
Combustion Air Maghelic (Inches Of Water)	3 - 5	
Fuel Gas Pressure Maghelic (Inches Of Water)	0-11	
Are there any Gas Leaks or Odor (Yes/No/Specify)	N	<input type="checkbox"/> Y <input type="checkbox"/> N
Damber Position		
Fresh Air Damper (% Open)	0-100	
Combustion Blower (% Open)	0-100	
Fuel Valve (% Open)	0-100	
Chamber Flushing (% Open)	0-100	
Process Isolation Damper (Open /Close)	Open	
Recirculation Damper (% Open)	0-100	
Are there any unusual odors, sounds, or signs of equipment wear? (Yes/No/Specify)	No	<input type="checkbox"/> Y <input type="checkbox"/> N
MAIN CONTROL ROOM		
Variable Speed Drive for Exhaust Fan		
Motor Hertz Hz	0-100	
CONTROL PANEL		
HVAC Unit		
Is the air circulation fan running? (Yes / No)	Y	<input type="checkbox"/> Y <input type="checkbox"/> N
Control Room Air Temperature (°F)	65-75	<input type="checkbox"/> Y <input type="checkbox"/> N
HIM (Operator Interface)		
Were there any alarms in the last day? (Yes/No/Specify)	N	<input type="checkbox"/> Y <input type="checkbox"/> N
Temperature Strip Chart Recorder		
Is the "RECORD: function on? (Yes/No)	Y	<input type="checkbox"/> Y <input type="checkbox"/> N
Is the chart recorder scanning through three points? (Yes/No)	Y	<input type="checkbox"/> Y <input type="checkbox"/> N
Change Chart Paper (Yes/No)	N	<input type="checkbox"/> Y <input type="checkbox"/> N
Burner Chamber Temperature (°F)	0-1800	
Exhaust Outlet Temperature (°F)	0-600	
Process Inlet Temp. (°F)	0-300	

